

**LICENSEE EVENT REPORT**

Attachment to AECM-83/0103  
Page 1 of 1

Page 1 of 1

CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ] (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	(2)	0	0	-	0	0	0	0	-	0	0	(3)	4	1	1	1	1	1	(4)			(5)
7	8	LICENSEE CODE						14	15	LICENSE NUMBER									25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT  
SOURCE

REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 0 1 2 3 8 3 8 0 2 2 2 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On January 23, 1983, while in shutdown, one air start receiver for Diesel Generator 12 was found pressurized to 125 psig. This pressure is less than the minimum required by T.S.4.8.1.1.2.a.7. As a result, Diesel Generator 12 and Division 2 ECCS were declared inoperable per T.S.4.0.3. This event had no effect on the health and safety of the public and did not constitute a threat to plant safety. The event is reported pursuant to T.S.6.9.1.13.b.

0	8		8
7	8	9	

SYSTEM CODE [ 0 ] [ 9 ] 7 8		CAUSE CODE [ E ] [ E ] (11) 9 10		CAUSE SUBCODE [ C ] (12) 11		COMPONENT CODE [ A ] [ I ] [ R ] [ D ] [ R ] [ Y ] (14) 13 18				COMP. SUBCODE [ Z ] (15) 19		VALVE SUBCODE [ Z ] (16) 20	
(17) LER/RO REPORT NUMBER [ 8 ] [ 3 ] 21 22		EVENT YEAR [ 8 ] [ 3 ] 21 22		SEQUENTIAL REPORT NO. [ 0 ] [ 3 ] [ 7 ] 24 26		OCCURRENCE CODE [ 0 ] [ 3 ] 28 29		REPORT TYPE [ 1 ] 30		REVISION NO. [ 0 ] 32			
ACTION TAKEN [ E ] (18) 32		FUTURE ACTION [ Z ] (19) 34		EFFECT ON PLANT [ Z ] (20) 35		SHUTDOWN METHOD [ Z ] (21) 36		HOURS [ 0 ] [ 0 ] [ 0 ] (22) 37 40		ATTACHMENT SUBMITTED [ N ] (23) 41		NPRD-4 FORM SUB. [ N ] (24) 42	
PRIME COMP. SUPPLIER [ A ] (25) 43		COMPONENT MANUFACTURER [ K ] [ 0 ] [ 0 ] [ 5 ] (26) 44 47											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The reason for the low pressure has been attributed to a stuck valve on the inlet to  
11 the air dryer for the electric driven air compressor. The problem with the stuck  
12 valve was corrected and the compressor automatically pressurized the receiver to  
13 greater than 160 psig. Diesel Generator 12 and ECCS Division 2 were returned to  
14 service on the same day. This is a final report.

7 8 9  
FACILITY STATUS (28) 1 5 B  
% POWER 0 0 0 (29)  
OTHER STATUS (30) NA  
METHOD OF DISCOVERY (31) A  
DISCOVERY DESCRIPTION (32) Alarmed Condition

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  
1 6 Z (33) Z (34) NA  
NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES		TYPE		DESCRIPTION	
NUMBER					
1	0	0	0	(37)	7
2	0	0	0	(38)	1

NA

7	8	9	11	12	13	80
PERSONNEL INJURIES						
NUMBER			DESCRIPTION (41)			

NUMBER		DESCRIPTION	
1	8	0 0 0	40 NA
7	8	9	11 12

LOSS OF OR DAMAGE TO FACILITY

1 9		Z		42		NA	

7 8 9 10  
PUBLICITY  
ISSUED DESCRIPTION (45)  
3 6 M (44)  
8302280234 830222  
PDR ADOCK 05000416  
S PDR  
NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER

PHONE:

000 017.926