

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

SUPPLEMENTAL INFORMATION TO
LER 82-047/03 X-1

Mississippi Power & Light Company
Grand Gulf Nuclear Station - Unit 1
Docket No. 50-416

Technical Specification Involved: 4.4.6.1.4.b

Event Narrative:

This is an update to a previous report submitted on September 28, 1982. The following paragraph describes the event which occurred on August 30, 1982.

During tensioning of the RPV head, temperatures of the vessel flange and head flange were not verified to be greater than or equal to 70°F prior to tensioning and at least every 30 minutes thereafter as required per Technical Specification 4.4.6.1.4.b. Upon observance of this non-compliance, the required temperatures were recorded at the proper frequency in the control room log at the time, maintenance instruction 07-S-14-184 did not require logging the temperatures. Recorded temperatures varied by 1°F and were well over the minimum of 70°F for the remaining duration of the evolution.

Maintenance instruction, 08-S-14-184 was revised on January 10, 1983, to reference a new procedure, 06-OP-1B13-V-0001, which will record the temperatures at the required locations and frequency as specified in Technical Specification 4.4.6.1.4.b. This event was not of major significance based on the above information. This is a final report.