



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

May 19, 1995

TVA-SQN-TS-95-13

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of  
Tennessee Valley Authority

)  
)

Docket No. 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS)  
CHANGE 95-13, "EXTENSION OF RESPONSE TIME SURVEILLANCE REQUIREMENTS  
FOR UNIT TWO CYCLE SEVEN"

In accordance with 10 CFR 50.90, we are enclosing an amendment to License DPR-79 to change the TSs of SQN Unit 2. The proposed change revises the License Condition 2.C.(17) to extend response time surveillances during the Unit 2 Cycle 7 operation. This extension will delay the performance to May 4, 1996, for the 36-month surveillances required by TS Surveillance Requirement 4.3.2.1.3, but will not exceed the 25 percent allowable extension provided by TS 4.0.2 by more than four and one-half months.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant safety hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3.

The response time surveillances that are proposed to be extended will begin to exceed the allowable extension provided by TS 4.0.2 on December 20, 1995. TVA requests approval of the proposed revision before December 1995 to allow continued operation of Unit 2 until the Cycle 7 refueling outage currently scheduled for April 19, 1996.

TVA requests a 30-day implementation period for this TS change following issuance.

9505260216 950519  
PDR ADOCK 05000328  
P PDR

DD301

U.S. Nuclear Regulatory Commission

Page 2

May 19, 1995

Please direct questions concerning this issue to Keith Weller at (615) 843-7527.

Sincerely,

*R. H. Shell*

R. H. Shell  
Manager  
SQN Site Licensing

Sworn to and subscribed before me  
this 19<sup>th</sup> day of May 1995

*Gregory M. Bullinsley*  
Notary Public  
My Commission Expires Oct. 21, 1998

Enclosures

cc: See page 3

U.S. Nuclear Regulatory Commission

Page 3

May 19, 1995

(Enclosures):

Mr. D. E. LaBarge, Project Manager  
Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852-2739

Mr. Michael H. Mobley, Director (w/o Enclosures)  
Division of Radiological Health  
3rd Floor  
L & C Annex  
401 Church Street  
Nashville, Tennessee 37243-1532

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323-2711