



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
P.O. Box 220
St. Francisville, LA 70775
(504) 336-6225
FAX (504) 635-5068

JAMES J. FISICARO
Director
Nuclear Safety

May 19, 1995

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop P1-37
Washington, D.C. 20555

Subject: Revision To River Bend Station Commitment: Initiation of Condition Reports
During Performance of ASME Section XI Pump and Valve Surveillance Testing
River Bend Station - Unit 1
Docket No 50-458

File No.: G9.5, G1.47

RBF1-95-0128
RBG-41531

Gentlemen:

The purpose of this letter is to inform the staff of a change to a previous River Bend Station (RBS) commitment. In our response to Notice of Violation 50-458/92-22-01, RBS stated, in part, that "Additional action will be taken to review and reinforce the present steps in other IST STPs (which presently total to approximately 150 STPs, soon to be 180 STPs) to ensure that condition reports are generated when multiple or recurring failures happen, or required actions occurs on certain ASME XI pumps and valves."

Subsequent to our response, RBS determined that a revision to upper-tier documents that control both the Condition Report process and the Surveillance Test Program would be an efficient means of accomplishing the above action. RBNP-030 (Condition Reports) and ADM-015 (Surveillance Test Program) were changed to require that a condition report be generated for test data determined unacceptable during ASME Section XI testing. We believe that this change ensures that unacceptable test data is documented and appropriate actions are taken.

950526034B 950519
PDR ADOCK 0500043B
P PDR

A047 1/0

Revision To River Bend Station Commitment: Initiation of Condition Reports During Performance of ASME Section XI Pump and Valve Surveillance Testing


May 19, 1995

RBF1-95-0128

RBG-41531

This document will serve as our official notification to the Staff of the above change. Should you have any questions or require additional information, please contact Ms. Jewel Summers at (504) 336-6345.

Sincerely,



JJF/JS/kvm

cc: NRC Sr. Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

US Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Mr. David Wigginton
NRR Project Manager
U.S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3, One White Flint North
11555 Rockville Pike
Rockville, MD 20852