

CONTROL BLOCK: 

--	--	--	--	--	--

LICENSEE  
NAME

LICENSE NUMBER

LICENSE  
TYPE

EVENT  
TYPE

NAME		LICENSE NUMBER										TYPE					TYPE			
01	ILDRS2	00	-	00	00	00	-	00	4	1	1	1	1	0	3					
7	8	9											25	26				30	31	32

01		CON'T		CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE						REPORT DATE					
7	8	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80		
				L	L	0	5	0	-	0	2	3	7	0	7	2	7	7	6	0	8	2	4	7	6		

02 DURING ROUTINE SURVEILLANCE TESTING, DRYWELL HIGH PRESSURE ECCS INITIA-  
7 8 9 80

03 TION SWITCH PS 1632A WAS FOUND TO ACTUATE AT 2.04 PSI (TECH SPEC LIMIT: LESS  
7 8 9 80

04 THAN OR EQUAL TO 2.00 PSI). PS 1632A IS A DUAL CONTACT SWITCH FOR INITIATION OF  
7 8 9 80

05 THE LPCI, HPCI, AND CORE SPRAY SYSTEMS. ECCS OPERABILITY WAS ENSURED BY  
7 8 9 80

06 REDUNDANT PRESSURE SWITCHES 1632B, C, AND D. THE SETPOINT OF PS 1632A  
7 8 9 80

PRIME (SEE ATTACHED SHEET) 80

(SEE ATTACHED SHEET) 80

SYSTEM CODE		CAUSE CODE	COMPONENT CODE						COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION
07	S F	E	I	N	S	T	R	U	N	S	3	8	2	Y
7	8 9 10	11	12					17	43	44			47	48

09	IT IS NOT KNOWN WHETHER THE FAILURE WAS CAUSED BY INSTRUMENT SETPOINT DRIFT	80
09	OR BY MECHANIC ERROR. AS STATED ABOVE, IMMEDIATE CORRECTIVE ACTION WAS TO AD-	80
10	JUST THE SETPOINT OF PS 1632A TO 1.92 PSI. TO PREVENT RECURRENCE, PROCEDURE	80
	(SEE ATTACHED SHEET)	

(SEE ATTACHED SHEET) 80

NUMBER				TYPE	DESCRIPTION
13	0	0	0	Z	NA

NUMBER				DESCRIPTION
1	4	0	0	NA

15	NA
----	----

TYPE			DESCRIPTION
16	2		NA

17	NA
----	----

18 NA PDR ADDCK 05000237  
7 8 9 S PDR

8304040502 760824  
PDR ADDCK 05000237  
S PDR

19

7 8 9

BC

NAME: GREGG REIMERS

PHONE: EXT. 265

EVENT DESCRIPTION (Continued)

was adjusted to 1.92 psi. This is not a repetitive event.  
(50-237/1976-52)

CAUSE DESCRIPTION (Continued)

DIS-1600-5 will be reviewed with the instrument mechanics to ensure that these personnel thoroughly understand the instrument surveillance procedure. Additionally, PS 1632A will be checked monthly, and the as-found setpoints will be graphed and reviewed for 3 months to allow prompt identification of any unfavorable trends. Pressure switch 1632A is a Static-O-Ring model 12N-AA5 pressure sensor, with a range of .25-12 psi.



Commonwealth Edison  
Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

IE FILE COPY



BBS Ltr. #76-625

August 24, 1976

Mr. James G. Keppler, Regional Director  
Directorate of Regulatory Operations - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Enclosed please find Reportable Occurrence report number 50-237/1976-52.  
This report is being submitted to your office in accordance with the Dresden  
Nuclear Power Station Technical Specifications, Section 6.6.B.

B. B. Stephenson  
Station Superintendent  
Dresden Nuclear Power Station

BBS:jo

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
File/NRC

COPY SENT REGION



8778