

Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

TELETYPE UNIT: 6-16-76
Copies Date 6-16-76
of
Telegraphed GE 3:30 p.m.
DC
By KC

cc:
Director
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. D. Knapp of
your office at 3:08 p hrs this date concerning Instrument drift
on 2 Instruments. P.S. 2-263-55A & P.S. 2-
263-55C (Reactor Hi. pressure scram switches)
These switch had drifted 2# above the Tech.
Spec limit. These drifts were found on
the monthly surveillance for these instruments.

8304040609 760616
PDR ADDCK 05000237
S PDR

Arthur M. Roberts

To Call:

GE - 7-858-2660x16
DC - 9-1-301 492-7617 (auto)
WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (orig)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephones: 815-942-2920/2921x212
(telecopy x262)

REV. 12-75

6/16/76

Rec'd 392

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Commonwealth Edison Company 50-237
(Licensee & Docket No. (or License No.))

Transmittal Date: June 18, 1976 Dresden Station-Unit #2

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files