

[illegible]

REPORT SOURCE: 01 L 6 0 5 0 0 0 3 3 6 7 0 3 2 9 8 3 8 0 4 0 2 8 4 9

02 | The plant was in steady state operation at 100% power. During a surveillance
03 | test of a newly installed resistance temperature detector (RTD) the response
04 | time for the loop #1 Hot Leg, on channel D, was found to be out of specification
05 | in a non-conservation direction. The plant was operated in accordance with
06 | action statement 2b of Technical Specifications 3.3.1.1. Similar occurrences
07 | none.

0	8	9																80			
			SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE				
0	9	8	I	F	11	E	12	E	13	I	N	S	T	R	U	14	E	15	Z	16	
			EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.										
17	LER RO REPORT NUMBER	8	3	21	22	0	1	3	24	26	0	3	28	X	30	1	32				
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPR-4 FORM SUB		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER					
X	18	A	19	Z	20	Z	21	0	0	0	X	23	Y	24	N	25	R	3	6	9	26
37	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54

1 0 | The cause of the out of specification setpoint was RTD failure. The RTD was

1 1 | removed as a reactor protection system input via the bypass/jumper system. The

1 2 | Rosemount, Model 104AFC-1 RTD was replaced during the 1983 refuel outage. The

1 3 | replacement RTD (Weed, Model 612) will enhance the reliability of the reactor

1 4 | protection system.

FACILITY STATUS: 1 5 E (28) % POWER: 1 0 0 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Surveillance Test (32)

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 Z 33 Z 34 NA
2 8 9 10 11 44

LOCATION OF RELEASE (36)
NA
45

PERSONNEL EXPOSURES			
NUMBER	TYPE	DESCRIPTION	
0 0 0	(37) Z	(38)	NA

PERSONNEL INJURIES

NUMBER				DESCRIPTION	
1	h	0	0	0	NA
				40	8404240293 840402
					PDR ADCK 05000344

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION

1	9	3	42	NA
7	8	9	10	

PUBLICITY (45) ISSUED DESCRIPTION (45) N7A NRC USE ONLY

[illegible]

NAME OF PREPARER Keith D. Deslandes

PHONE (203) 447-1791 X4421

1-800-917-9280

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 666-6911

April 2, 1984
MP-5915

Dr. Thomas E. Murley
Regional Administrator, Region 1
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA. 19406

Reference: Provisional License DPR-65
Docket No. 50-336
Reportable Occurrence RO 50-336/83-13/3X-1

Dear Dr. Murley:

This letter forwards the updated Licensee Event Report for Reportable Occurrence RO 83-13/3X-1. An additional three copies of the report are enclosed.

Yours truly,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, appearing to read 'E. J. Mroczka'. The signature is written in dark ink and is positioned above the printed name.

E. J. Mroczka

Station Superintendent
Millstone Nuclear Power Station

EJM/KDD:mo

Attachment: LER RO 50-336/83-13/3X-1

cc: Director, Office of Inspection and Enforcement, Washington, D. C. (30)
Director, Office of Management Information and Program Control,
Washington, D. C. (3)
U. S. Nuclear Regulatory Commission, c/o Document Management Branch,
Washington, D. C. 20555

IE22
11