

TO:
Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: 12/15/76 *IE*

Teletypes

Date

12-15-76 *Files*

or

Telegraphed

GE

1:34 p.m.

DC

By BB

cc:

~~Director~~

~~Office of Management Information and Program Control~~

~~U.S. Nuclear Regulatory Commission~~

~~Washington, DC 20555~~

50-237

50-249

SUBJECT: DPR-19025 Dresden Nuclear Power Station, Unit 2 & 3

This will confirm a conversation with W. Schaeffer of
your office at 12:50 hrs this date concerning 4% reduction
in allowable MAPINER resulting from
an error in B.E. ECCS analysis.
Heat absorbed by reactor vessel and
components was inadvertently doubled.

J. S. Kolanowski

B304050094 761215
PDR ADOCK 05000237
S PDR

To Call:

GE - 7-358-2660x16

DC - 9-1-301-492-7617 (auto)

WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (orig)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212
(teletype x262)

Rev. 12-75

Received 1:50 12/15/76 jk