

Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
759 Roosevelt Road
Glen Ellyn, IL 60137

TELETYPE
Date 12-6-76
or
Telegraphed GR 4:15
DC
By BC

~~Office of Technical Information and Program Control~~
~~U.S. Nuclear Regulatory Commission~~
~~Washington, DC 20545~~

50-237

SUBJECT: NER-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with T. ESSIG of
your office at 1540 hrs this date concerning THE RECEIPT
OF AN EMPTY SPENT FUEL SHIPPING CASK ON
12-6-76 WHICH HAD SOME AREAS OF REMOVABLE
SURFACE CONTAMINATION GREATER THAN 22,000
d/imp/100cm². THIS CASK WAS RECEIVED FROM GEE
IMPORTS OPERATION.

To Call:

GR - 7-858-2540x18
NR - 9-1-301-402-7617 (auto)
WB - 815-942-4649/4321

Station Dist: Originator (copy)
Incident File (copy)
Reference File (info)

B. E. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
P.O. Box
Morris, IL 60450

Telephone: 815-942-2926/2921x212
(telecopy 22621)

Encl. 12-73