

101:  
Regional Director  
Directorate of Regulatory Operations  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

MAILS: 12-1-76

Teletype

Date 12-2-76

or

Teleprinted

GE

DC

By

001-

Director-

Office of Management Information and Program Control

U.S. Nuclear Regulatory Commission

Washington, DC 20555

50-237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2

This will confirm a conversation with T. ESSIG of  
your office at 0930 hrs this date concerning THE RECEIPT OF  
AN EMPTY SPENT FUEL SHIPPING CASK FROM GEB MORRIS  
OPERATION WHICH HAD SOME AREAS OF REMOVED  
SURFACE CONTAMINATION GREATER THAN 22000 d/m/100cm<sup>2</sup>.  
THIS CASK WAS SURVEYED ON 12-1-76 AT 1530 HRS.

8304050121 761202  
PDR ADDCK 05000237  
S PDR

To Call:

GE - 7-558-2660x16

DC - 9-1-301-492-7617 (auto)

WU - 815-942-4449/4321

B. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Station Dist: Originator (copy)  
Incident File (copy)  
Palmer File (orig)

Telephone: 815-942-2920/2921x212  
(teletype 4762)

REV. 12-75

Rec'd 9:56 12/2/76