

U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Telegraphed GE 8 303 171

DC

cc:  
Director  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

By KC

50-237

SUBJECT: DPR-19, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Whene Shaffer of your office at 2:15 PM hrs this date concerning the failure of 4PC1 Valve 40-2-2301-8 (NPC1 injection line valve). Unit 2 has been shutdown for a maintenance outage. When the outage started the 2-2301-8 valve was inspected and found to have a broken stem. During operation the valve had a ground on it and so had been placed in the open position and then Electrically Locked O.O.S.

11/13/76

8304050143 770513  
PDR ADDCK 05000237  
S PDR

To Call:  
GE - 7-855-2560x16  
DC - 9-1-301-492-7617 (auto)  
WU - 815-942-4449/4321

R. B. Stephenson, Superintendent  
Dresden Nuclear Power Station  
Commonwealth Edison Company  
R.R. #1  
Morris, IL 60450

Station Dist: Originator (copy)  
Incident File (copy)  
Telegram File (copy)

Telephone: 815-942-02921x212  
(teletype x262)

Rev. 12-75