

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME 01 N Y R E G 1										LICENSE NUMBER 0 0 - 0 0 0 0 0 - 0 0										LICENSE TYPE 4 1 1 1 1					EVENT TYPE 0 3			
CATEGORY 01 CONT P O										REPORT TYPE L		REPORT SOURCE L		DOCKET NUMBER 0 5 0 - 0 2 4 4					EVENT DATE 1 0 1 2 7 5					REPORT DATE 1 1 0 4 7 5				

EVENT DESCRIPTION

02 During startup with reactor critical, reactor coolant temp. over 500 F, I-131 equivalent activity was reported to be at 5.43 micro Ci/gm, a degraded condition permitted by limiting conditions for operation. Increased primary coolant sampling was begun with increasing purification flow to max. The I activity was returned to less than 3 micro Ci/gm in about 9 hrs. (Unusual Event 50-244/75-09)

SYSTEM CODE R C		CAUSE CODE E		COMPONENT CODE F U E L X X				PRIME COMPONENT SUPPLIER N		COMPONENT MANUFACTURER W 1 2 0				VIOLATION N	
--------------------	--	-----------------	--	-------------------------------	--	--	--	-------------------------------	--	-----------------------------------	--	--	--	----------------	--

CAUSE DESCRIPTION

08 A partial cooldown and subsequent heatup and the accompanying depressurizing and pressurizing of the fuel resulted in the increased reactor coolant I-131 equivalent activity.

FACILITY STATUS C		% POWER 0 0 0		OTHER STATUS NA		METHOD OF DISCOVERY a		DISCOVERY DESCRIPTION sampling per startup procedure			
FORM OF ACTIVITY RELEASED Z		CONTENT OF RELEASE Z		AMOUNT OF ACTIVITY NA		LOCATION OF RELEASE NA					

PERSONNEL EXPOSURES

NUMBER 0 0 0		TYPE Z		DESCRIPTION NA	
-----------------	--	-----------	--	-------------------	--

PERSONNEL INJURIES

NUMBER 0 0 0		DESCRIPTION NA	
-----------------	--	-------------------	--

OFFSITE CONSEQUENCES

TYPE Z		DESCRIPTION NA	
-----------	--	-------------------	--

LOSS OR DAMAGE TO FACILITY

TYPE Z		DESCRIPTION NA	
-----------	--	-------------------	--

PUBLICITY

TYPE Z		DESCRIPTION NA	
-----------	--	-------------------	--

ADDITIONAL FACTORS

TYPE Z		DESCRIPTION NA	
-----------	--	-------------------	--

8304050195 751104
 PDR ADOCK 05000244
 S PDR

NAME: Bruce A. Snow

PHONE: 716/546-2700, ext. 291-214



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

November 4, 1975

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Unusual Event 75-09, Reactor Coolant Iodine-131 Equivalent
Activity
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:

In accordance with Technical Specifications, Article 6.6.2b, the attached report of Unusual Event 75-09 is hereby submitted. Two additional copies of this letter and the attachment are enclosed.

Very truly yours,

L. D. White, Jr.

Attachment

cc: Mr. Donald F. Knuth (30)
Mr. William G. McDonald (3)