



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

NEW YORK STATE



TELEPHONE
AREA CODE 716 546-2700
Ginna Station
February 5, 1975

Mr. J. P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Directorate of Regulatory Operations
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Abnormal Occurrence 75-02 - Failure of the 1C Safety Injection Pump to Start Manually from Bus 16
Ginna Station Docket #50-244

Dear Mr. O'Reilly:

This is to confirm my phone call to Mr. John Hannon this morning to report Abnormal Occurrence 75-02 at Ginna Station.

While conducting Periodic Test (PT-2.1), and following the satisfactory test of the 1-A and 1-B Safety Injection Pumps, the 1-C Safety Injection Pump which can be operated from either Bus 14 or Bus 16, failed to start manually on Bus 16 the first time it was tried. The 1-C pump was started from Bus 14 and the pump test completed. The pump was tried from Bus 16 twice since the malfunction and operated successfully.

The PORC met and recommended a thorough inspection of the breaker by the Electricians. Any further action that is necessary will be carried out after the Electricians report back to PORC.

Very truly yours,

Lee S. Lang

Lee S. Lang
Assistant Superintendent

LSL:bg

cc: Mr. J. F. O'Leary, NRC
Mr. G. J. Swarthout, RG&E
Mr. L. D. White, Jr. RG&E

8304060026 750214
PDR ADGCK 05000244
S PDR

50-244
inquiry

1506

COPY SENT REGION I