



Telegram

LD 018 TDVE CORDOVA, ILLINOIS JULY 16, 1972 12:10P

MR EDWARD JORDEN
REGION 3 COMPLIANCE
U S ATOMIC ENERGY COMM
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS

RE: SQUAD-CITY NUCLEAR POWER STATION UNIT 2-DRP-30 APPENDIX A
SECTIONS 6.6.A.3 AND 6.6.B.3 AT 3AM ON 7/16/72 A SMALL FIRE WAS
DISCOVERED IN TWO ELECTRICAL CABLE TRAYS. THE REACTOR WAS OPERATING
AT 80 PERCENT POWER AND A CONTROL SHUT DOWN WAS ORDERED THE
GENERATOR WAS OFF SYSTEM AT 5:37AM 7/16/72. THE REACTOR PROTECTION
SYSTEM REMAINED OPERABLE AND BOTH PRIMARY AND SECONDARY CONTAIN-
MENT SYSTEM WERE MAINTAINED. THE ONLY DEGRADATION OF SAFETY RE-
LATIVED SYSTEM WAS THE INABILITY TO CLOSE THE SUCTION AND DISCHARGE

WU 1201 (R 5-69)

VALVES FOR THE TWO B REACTOR CIRCULATION PUMP BECAUSE OF THE
FIRE DAMAGE CONTROL WIRING. THE FIRE WAS EXTINGUISHED USING PORTABLE
CARBON DIOXIDE EXTINGUISOR. INVESTIGATION OF CAUSE IS IN PROGRESS.

B STEPHENSON

8304060112 720821
PDR ADOCK 05000265
S PDR

JUL 19 1972

2 1038

WU 1201 (R 5-69)