

ATTACHMENT 3

TECHNICAL SPECIFICATION PAGE 3/4 3-72 FOR ACTION 42 c.

9505310176 950525
PDR ADOCK 05000498
P PDR

TABLE 3.3-10 (Continued)

ACTION STATEMENTS (Continued)

- c. With the number of OPERABLE channels less than 4 thermocouples per quadrant, restore these thermocouples to OPERABLE status within 48 hours, or be in at least HOT SHUTDOWN within the next 12 hours.

ACTION 43 -

- a. With the number of OPERABLE channels two less than the Total Number of Channels requirements, restore the inoperable channel to OPERABLE status within 31 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE channels three less than the Total Number of Channels requirement, restore at least one inoperable channel to OPERABLE status within 7 days, or be in at least HOT SHUTDOWN within the next 12 hours.
- c. With the number of OPERABLE channels less than the Minimum Channels Operable requirement, restore at least one inoperable channel to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.

TSC-95/95-138.001