

March 30, 1984
(NMP2L 0020)

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

The following provides our response to I.E. Bulletin 83-08, Electrical Circuit Breakers with an Undervoltage Trip Feature in Use in Safety-Related Applications Other Than the Reactor Trip System.

No Westinghouse Type DB or DS or General Electric Type AK-2 circuit breakers are used in safety-related applications other than the reactor trip system at Nine Mile Point Unit 2; therefore, this bulletin is not applicable to Nine Mile Point Unit 2.

To assist the Nuclear Regulatory Commission in evaluating the cost of this bulletin, we are providing the following information:

1. Approximately ten man-hours were used to perform the requested review.
2. Approximately five man-hours were used to prepare the requested documentation.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President
Nuclear Engineering & Licensing

CVM/TL:ja
xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, Resident Inspector

8404260131 840330
PDR ADOCK 05000410
G PDR

11 IE 11

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

Niagara Mohawk Power Corporation)

(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C.V. Mangan, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 30th day of March, 1984.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires March 30, 1985