

LICENSEE EVENT REPORT

CONTROL BLOCK:

1					6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME					LICENSE NUMBER					LICENSE TYPE					EVENT TYPE	
0	1	N	Y	N			-			4	1	1	1	1	0	3
7	8	9		14	15				25	26			30	31	32	

01		CON'T		CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE						REPORT DATE					
7	8	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80		
				L	L	0	5	0	-	0	2	2	0	0	3	2	6	7	7	0	4	1	4	7	7		

[illegible]

02	During routine calibration of emergency condenser vent monitor, found indication of	80
03	50 mr/hr when test source should have produced indication of only 6 mr/hr. Since	80
04	trip point was set at 25 mr/hr and checked as correct, emergency condenser would	80
05	have isolated at lower than the specified radiation.	80
06		80

LER 77-14

7 8 9 10 11 12 13 14 15 16 17 43 44 45 46 47 48

SYSTEM CODE CAUSE CODE COMPONENT CODE PRIME COMPONENT SUPPLIER COMPONENT MANUFACTURER VIOLATION

07 BB F INSTRU O G080 N

CAUSE DESCRIPTION

08	Reset output of detector to produce monitor readings corresponding to the test	80
09	source. Response as found would have been conservative.	80
10		80

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	G	0	0	0	NA		B		NA	
7	8	9	10	11	12	13	44	45	46	80

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
1	2	Z	NA	NA
7	8	9	10	11
				44
				45
				80

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION
1	3	0	0	0	Z NA
7	8	9	11	12	13 80

PERSONNEL INJURIES

NUMBER				DESCRIPTION	
1	4	0	0	0	NA

~~XXXXXX~~ CONSEQUENCES PROBABLE

1	5	NA
7	8	9

LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION
1	5	Z	NA

7 8 9 10

PUBLICITY
 NA
 8304060350 770414
 PDR ADOCK 05000220
 S PDR

ADDITIONAL FACTORS

13 | Also found monitor reading of 600 vs. source of 45. All readings within the
7 8 9 | allowable instrument deviation of +100%-50% when reset. 80

[illegible]