

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME														LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	N	Y	N	M	P	1									4	1	1	1	1	0	4									
7	8	9				14	15									25	26			30	31	32								
CON'T		CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE					REPORT DATE											
01			-	-	T	1							1	0	1	9	7	6	1	0	2	5	7	6						
7	8		57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80				

## EVENT DESCRIPTION

02	July 1976 Monthly Chemical Proportional Composite was inadvertently discarded																							
7	8	9																						80
03	prior to performing chemical liquid waste analyses, which are required per																							
7	8	9																						80
04	Appendix B, Table 2.3-2. The composite sample was discarded because it was not																							
7	8	9																						80
05	promptly labelled after preparation.																							
7	8	9																						80
06	LER 76-37																							
7	8	9																						80

SYSTEM CODE				CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION			
07	Z	Z				Z	Z	Z	Z	Z	Z	--		Z	9	9	9	--	
7	8	9	10		11	12						17	43	44			47		48

## CAUSE DESCRIPTION

08	Technician did not label composite sample prior to being called away on another																							
7	8	9																						80
09	job, and it was poured out during routine lab clean-up. Commenced procedural																							
7	8	9																						80
10	review to clarify requirements for compositing.																							
7	8	9																						80

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION													
11	E			Z	Z	Z	N/A			Z	Management review of analyses													
7	8	9		10	11	12	13			44	45	46												80
FORM OF ACTIVITY RELEASED			CONTENT OF RELEASE			AMOUNT OF ACTIVITY			METHOD OF DISCOVERY		LOCATION OF RELEASE													
12	Z			Z	N/A			N/A			N/A													
7	8	9		10	11	12	13			44	45													80

## PERSONNEL EXPOSURES

NUMBER			TYPE		DESCRIPTION																				
13	0	0	0	Z	N/A																				
7	8	9		11	12	13																			80

## PERSONNEL INJURIES

NUMBER			DESCRIPTION																					
14	0	0	0	N/A																				
7	8	9		11	12																			80

## ON-SITE CONSEQUENCES PROBABLE

15	None																							
7	8	9																						80

## LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION																					
16	Z	N/A																						
7	8	9		10																				80

## PUBLICITY

17	N/A																							
7	8	9																						80

8304060438 761025  
PDR ADOCK 05000220  
S PDR

## ADDITIONAL FACTORS

18	Reviewed requirements for compositing with technician responsible including																							
7	8	9																						80
19	procedural requirement for promptly reporting problems encountered.																							
7	8	9																						80

NAME: E.W. Leach

PHONE: 315-343-2110 (1303)

NIAGARA MOHAWK POWER CORPORATION

IE FILE COPY

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST  
SYRACUSE, N. Y. 13202

October 25, 1976

Mr. James P. O'Reilly  
Director  
United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA. 19406


RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Report 76-37.

This report was completed within the intent of the Licensee Event Report Instruction Booklet OOE-SS-001, dated October 1974, revised December 24, 1974. Due to the minimal significance category of this report, no supplemental report is included.

Very truly yours,

  
R.R. Schneider  
Vice President -  
Electric Production

TJD/mtm

Enc.

11169

