

WESTERN UNION INCOMING

1972 JUN 11 AM 8 44

U.S. ATOMIC ENERGY COMMISSION
THE UNIT

50-254

USACED HUS GJWN

ALL

WU HSR

TELETYPE TO DIRECTOR, AEC

RE THRU: US PDR 100N CONDOMA LLL IR 10314 COT

EDWARD J. BLOCH, ACTING DIRECTOR DIRECTORATE OF LICENSING

FOR RECORD: DIRECTOR, COMMISSION, WASHINGTON, D.C.

REFERENCE QUAD CITIES NUCLEAR POWER STATION UNIT ONE DRY-
DOWN A SECTIONS 1.0.A.2, 6.6.A.3 AND 6.6.B.3 AT 505PM ON
JUNE 11, 1972 WITH THE UNIT ONE REACTOR IN A SHUT-DOWN MODE.
THE NORTHEAST EXPANSION JOINT ON THE CONDENSOR CIRCULATING
WATER SYSTEM CAPTURED. THE UNIT ONE CONDENSATE PUMP ROOM WAS
FLOODED. THE FLOODING AFFECTED THE FOLLOWING:

FOR EQUIPMENT:

FOUR UNIT ONE RESIDUAL HEAT REMOVAL SYSTEM SERVICE WATER PUMPS,
THE UNIT ONE AND UNIT ONE TWO DIESEL GENERATOR COOLING WATER
PUMPS, CONDENSATE TRANSFER PUMPS, AND THE UNIT ONE CONDENSATE
AND CONDENSATE BOOSTER PUMPS. THIS EQUIPMENT WAS DECLARED INOPERABLE.

THE UNIT TWO REACTOR WAS IN THE START UP MODE AT THE TIME
OF THE INCIDENT AND WAS SHUT DOWN IMMEDIATELY.

RE STEPHENSON QUAD CITIES NUCLEAR POWER STATION


DRY-
DOWN A 1.0.A.2 6.6.A.3 6.6.B.3 505PM JUNE 11, 1972.

(4P JUNE 10)

ON LINE VIA

MAJOR EQUIPMENT: IRS

B304060450 720901
PDR ADOCK 05000254
S PDR



50-254
incident

3141