

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME: 01 N Y N M P 1
 7 8 9 14
 LICENSE NUMBER: 15 25
 LICENSE TYPE: 26 30
 EVENT TYPE: 31 32
 CATEGORY: 01 CON'T - -
 7 8 57 58
 REPORT TYPE: L
 59
 REPORT SOURCE: L
 60
 DOCKET NUMBER: 0 5 0 - 0 2 2 0
 61 68
 EVENT DATE: 0 8 2 7 7 6
 69 74
 REPORT DATE: 0 9 2 3 7 6
 75 80

[illegible]

02	During surveillance testing (RE-22), Main Steam Line Break Instrumentation, it was	80
03	found that RE-22A tripped at 108psig rather than the required value of 105±1 psig.	80
04	All redundant instruments preformed properly, thus no hazard was presented to	80
05	the general public.	80
06	LER 76-32	80
	SYSTEM CAUSE PRIME	80

SYSTEM CODE: 07
 CAUSE CODE: E
 COMPONENT CODE: INSTRTU
 PRIME COMPONENT SUPPLIER: A
 COMPONENT MANUFACTURER: B080
 VIOLATION: -

CAUSE DESCRIPTION

08	The Barton Model 278, Serial Number 759, was inspected for mechanical defects	
7 8 9		
09	and friction. No reason other than set point drift could be found. RE-22A	80
7 8 9		
10	was recalibrated and returned to service.	80
7 8 9		

FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			80
1	1	E			0	9	4	b		N/A			
7	8	9	10	12	13		44	45	46				80
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY					LOCATION OF RELEASE				
1	2	Z		Z			N/A		N/A				
7	8	9	10	11		44	45						

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION	
1	3	0	0	0	2	N/A

PERSONNEL INJURIES

NUMBER				DESCRIPTION	
1	4	0	0	0	N/A

~~DEATH~~ CONSEQUENCES PROBABLE

1	5	None
7	8	9

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION
16	Z	N/A

PUBLICITY

17 None

ADDITIONAL FACTORS

1	5	None	9	PDR
---	---	------	---	-----

19

NAME: _____

PHONE:

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

September 24, 1976

Mr. James P. O'Reilly
Directorate of Regulatory Operations
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pa. 19406



RE: Docket No. 50-220

Dear Mr. O'Reilly:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specification 6.9, we hereby submit Licensee Event Reports 76-32 and 76-33.

These reports were completed within the intent of the Licensee Event Report Instruction Booklet 00E-SS-001, dated October, 1974, revised December 24, 1974. Due to the minimal significance category of these reports, no supplemental report is included.

Very truly yours,

Original Signed by R.R. Schneider

R.R. Schneider
Vice President -
Electric Production

TJD/mtm

Enc.

10074

COPY SENT REGION 