

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME										LICENSE NUMBER										LICENSE TYPE					EVENT TYPE	
01	N	Y	N	M	P	1	6	-									4	1	1	1	1	0	1			
7	8	9				14	15									25	26						31	32		

CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER										EVENT DATE					REPORT DATE					
01	CONT	M	I	L	L	0	5	0	-	0	2	2	0	0	6	2	7	7	6	0	7	0	1	7	6	
7	8	57	58	59	60	61							68	69						74	75					80

EVENT DESCRIPTION

02	During weekly surveillance testing of the APRM's, #11 & #15 APRM's failed to produce	80
03	a scram signal at the required flow bias set point. 20% flow test tripped higher	80
04	than required by less than 1%. All redundant (6) APRM's operable.	80
05		80
06	RO 76-25	80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE										PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER					VIOLATION	
07	R	B	F	I	N	S	T	R	U	N	G	0	8	0	-							
7	8	9	10	11	12				17	43	44			47	48							

CAUSE DESCRIPTION

08	Set point drift. Instruments calibrated to required specifications.	80
09		80
10		80

FACILITY STATUS		% POWER		OTHER STATUS										METHOD OF DISCOVERY		DISCOVERY DESCRIPTION												
11	E	0	9	8										b														
7	8	9	10	12	13									44	45	46												

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY										LOCATION OF RELEASE														
12	2	2	N/A																									
7	8	9	10	11										44	45													

PERSONNEL EXPOSURES

NUMBER			TYPE		DESCRIPTION									
13	0	0	0	2	N/A									
7	8	9	11	12	13									

PERSONNEL INJURIES

NUMBER			DESCRIPTION									
14	0	0	0	N/A								
7	8	9	11	12								

ONLINE CONSEQUENCES probable

15	NONE	80
----	------	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION									
16	2	N/A									
7	8	9	10								

PUBLICITY

17	NONE	80
----	------	----

ADDITIONAL FACTORS

18		80
----	--	----

B304060490 760701
PDR ADOCK 05000220
S PDR

19		80
----	--	----