

## LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1                          6

[PLEASE PRINT ALL REQUIRED INFORMATION]

01 N Y N M P 1 14 15 - - 25 26 4 1 1 1 30 31 0 3 32

01 CONT CATEGORY M 1 57 58 REPORT TYPE L 59 REPORT SOURCE L 60 61 0 5 0 - 0 2 1 2 0 68 69 0 4 2 3 7 6 74 75 0 5 2 1 7 6 80

[illegible]

02 During surveillance testing found 1B05C to actuate at 20.4 psid rather than required  
 03 19 psid. Switch is used to indicate emergency cooling high flow and isolate the  
 04 system. Redundant components operable that no hazard presented to plant or offsite  
 05 personnel.  
 06

## CAUSE DESCRIPTION

08	Setpoint drift which is within the expected range.										80	
09											80	
10											80	
11	FACILITY STATUS	% POWER			OTHER STATUS			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		80
11	c	0	6	0				b				80
12	FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE				80
12	z	z	N/A									80
PERSONNEL EXPOSURES												80

## PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION
13	000	3		N/A

PERSONNEL INVOLVED

80

## PERSONNEL INJURIES

NUMBER			DESCRIPTION
1	4	0 0 0	N/A

OFFENSE CONSEQUENCES      probable

1	5	NONE
7	8	9

## LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION
13	75		N/A

## PUBLICITY

17	NONE	PDR ADOCK 05000220
7 8 9		S PDR

### ADDITIONAL FACTORS