



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
April 24, 1984

FILE: B09-13510C
SERIAL: BSEP/84-1083

NRC Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 (2-SR-84-6)

Dear Sirs:

On March 31, 1984, a Unit 2 fire barrier LCO was initiated on penetration seal No. CB-2-327, fire door 222. This door, which is located on the 49-foot elevation of the Unit 2 Control Building, provides personnel access to the Unit 2 computer room from the Control Room. The LCO was initiated to permit opening the door to allow ambient air circulation between the computer room and the Unit 2 Control Room electronic equipment area due to the inoperability of the computer room air-conditioning unit.

On April 7, 1984, the LCO time frame expired. The required repairs to the subject air-conditioning unit were completed and on April 9, 1984, the LCO was cancelled and door 222 was returned to service.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/jlh/LETJH1

Enclosure

cc: Mr. James P. O'Reilly

8404260308 840424
PDR ADOCK 05000324
S PDR

LETJH
1/1