

CONTROL BLOCK:

1					6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME						LICENSE NUMBER								LICENSE TYPE					EVENT TYPE					
01	N	Y	R	E	G	1	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	3
7	8	9					15									25	26					30	31	32

CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER						EVENT DATE					REPORT DATE								
01	CON'T	L	L	0	5	0	-	0	2	4	4	1	2	1	7	7	6	0	1	1	1	7	7
7	8	57	58	59	60	61					68	69					74	75					80

[illegible]

02	During a dropped rod condition (see LER 76-28), core quadrant power tilt ratio calculation showed 1.125, in excess of limit of 1.12. Unit was placed in hot shutdown mode.	80
03	(Reportable Occurrence 76-29, 30-day).	80
04		80
05		80
06		80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE					COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION			
0	7	R	B	C	O	N	R	O	D	N	W	1	2	0	N		
7	8	9	10	11					12	17	43	44				47	48

CAUSE DESCRIPTION

08	Insertion of control rod F-12 with reactor at 48% power. Name plate data and	80
09	corrective action taken are described in LER 76-28.	80
10		80

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	E	048		NA		a		Quadrant power tilt calculation	
7	8	9	10	11	12	13	14	15	16
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
12	Z	Z		NA				NA	
7	8	9	10	11	12	13	14	15	16

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION
13	0	0	0	2	NA

PERSONNEL INJURIES

NUMBER				DESCRIPTION
14	0	0	0	NA

OFFSITE CONSEQUENCES

15	NA
----	----

LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION
16	2		NA

PUBLICITY

17 | NA | 80

ADDITIONAL FACTORS

18 NA S R ADDCK 05000244 PDR
7 8 9 80

19

7 8 9

NAME: G. F. Larizza

PHONE 716/546-2700, ext. 291-245



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

IE FILE COPY

January 11, 1977

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406



Subject: Reportable Occurrence 76-29 (30-day report), Quadrant to
average power tilt ratio
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:

In accordance with Technical Specifications, Article 6.9.2b, the attached report of Reportable Occurrence 76-29, 30-day, is hereby submitted. Two additional copies of this letter and the attachment are enclosed.

Very truly yours,

L. D. White, Jr.

Attachment

cc: Dr. Ernst Volgenau (30)
Mr. William G. McDonald (3)