

NRC Form 306  
(9-83)

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)	DOCKET NUMBER (2)	PAGE (3)
Grand Gulf Nuclear Station - Unit 1	0 5 0 0 0 4 1 6	1 OF 0 1

TITLE (4)
Control Room Fresh Air Auto Start

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)								
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)							
0	3	26	8	4	0	1	5	0	0	0	4	2	3	8	4	NA	0 5 0 0 0

OPERATING MODE (9)	4	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)									
		20.402(b)	20.406(c)	X	50.73(a)(2)(iv)	73.71(b)					
		20.406(a)(1)(i)	50.36(c)(1)		50.73(a)(2)(v)	73.71(c)					
		20.406(a)(1)(ii)	50.36(c)(2)		50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 355A)					
		20.406(a)(1)(iii)	50.73(a)(2)(i)		50.73(a)(2)(viii)(A)						
POWER LEVEL (10)	0 1 0 0	20.406(a)(1)(iv)	50.73(a)(2)(ii)		50.73(a)(2)(vii)(B)						
		20.406(a)(1)(v)	50.73(a)(2)(iii)		50.73(a)(2)(x)						

LICENSEE CONTACT FOR THIS LER (12)		TELEPHONE NUMBER	
NAME	Jerry Parker / Licensing Engineer	AREA CODE	6 0 1 4 3 7 - 2 1 4 9

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs

SUPPLEMENTAL REPORT EXPECTED (14)		EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
YES (If yes, complete EXPECTED SUBMISSION DATE)	X NO				

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 1124 hours on March 26, 1984, while the plant was in Cold Shutdown, the "B" Control Room Fresh Air Unit was inadvertently started in the isolation mode. A contractor electrical technician was preparing to replace a relay by jumpering the power supply around it. Due to the close proximity of other terminals, he touched one with the jumper. This caused a relay to drop out which automatically started the Control Room Fresh Air Unit. This event has no safety consequences. This is a final report.

8404270034 840423  
PDR ADOCK 05000416  
S PDR

IE22  
1/1



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 23, 1984

NUCLEAR PRODUCTION DEPARTMENT

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File: 0260/L-835.0  
Control Room Fresh Air Unit Auto  
Start  
LER 84-015-0  
AECM-84/0227

Attached is Licensee Event Report (LER) 84-015-0 which is a final report.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

EBS/SHH:rg  
Attachment

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator (w/a)  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

IF22  
1/1