

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) D. C. COOK PLANT UNIT 2										DOCKET NUMBER (2) 0 5 0 0 0 3 1 1 6 1 OF 0 1				PAGE (3) 1 OF 0 1					
TITLE (4) ICE CONDENSER ICE BASKET WEIGHTS																			
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)									
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)						
0	3	2	0	8	4	8	4	0	0	4	1	9	8	4	0 5 0 0 0				
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)																	
5		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)					
POWER LEVEL (10)		20.406(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)					
01010		20.406(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 365A)					
		20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)									
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(vii)(B)									
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)									
LICENSEE CONTACT FOR THIS LER (12)																			
NAME A. A. BLIND TECHNICAL - ENGINEERING SUPERINTENDENT										TELEPHONE NUMBER AREA CODE 6 1 6 4 6 5 1 - 5 9 0 1									
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																			
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC									
X	B	C	C	O	N	D	W	1	2	0	N								
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR			
X YES (If yes, complete EXPECTED SUBMISSION DATE: ) NO														0	7	0	1	8	4

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

WHILE SHUTDOWN FOR A REFUELING OUTAGE, SOME ICE CONDENSER ICE BASKETS WERE DETERMINED TO BE BELOW TECHNICAL SPECIFICATION 3.6.5.1.d L.C.O. VALUE of 1220 LBS. PER BASKET (WITH A 95 PERCENT LEVEL OF CONFIDENCE) ON 03-20-84.

THE DEFICIENT ICE BASKETS WILL BE BROUGHT INTO SPECIFICATIONS BY EMPTYING THEM AND REFILLING THEM. PREVIOUS ICE ADDITION METHODS HAVE PROVIDED ENOUGH ICE TO MEET ACCEPTABLE ICE BASKET WEIGHTS, BUT SOME BASKETS WOULD BE BELOW ALLOWABLE VALUES AT THE NEXT WEIGHING PERIOD. THIS NEW METHOD OF ICE ADDITION SHOULD INSURE ACCEPTABLE ICE BASKET WEIGHTS AT THE NEXT SCHEDULED WEIGHING.

THE DEFICIENT ICE BASKETS ARE CURRENTLY BEING EMPTIED, REFILLED AND WEIGHED. THIS TASK WILL BE COMPLETED BY THE END OF THE OUTAGE.

THIS IS AN INTERIM REPORT, THE FINAL REPORT WILL BE SUBMITTED FOLLOWING COMPLETION OF THE ICE WEIGHING AND ADDITION PROGRAM.

8404270045 840419  
PDR ADOCK 05000316  
S PDR

IF 22



**INDIANA & MICHIGAN ELECTRIC COMPANY**

DONALD C. COOK NUCLEAR PLANT  
P.O. Box 458, Bridgman, Michigan 49106  
(616) 465-5901

April 19, 1984

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Operating License DPR-74  
Docket No. 50-316

Document Control Manager:

In accordance with the criteria established by 10CFR50.73  
entitled Licensee Event Reporting System, the following  
report/s are being submitted:

RO 84-004-0

Sincerely,

  
W.G. Smith, Jr.  
Plant Manager

/cbm

Attachment

cc: John E. Dolan  
J.G. Keppler, RO:III  
M.P. Alexich  
R.F. Kroeger  
H. Brugger  
E.R. Swanson, RO:III  
R.C. Callen, MPSC  
G. Charnoff, Esq.  
J.M. Hennigan  
R.O. Bruggee, EPRI  
INPO  
PNSRC  
J.F. Stietzel  
E.L. Townley  
Dir., IE  
Dir., MIPC

*IE22*  
*11*