

IE22

SUPPLEMENTARY INFORMATION

REPORT NO. : 50-302/82-033/03X-1

FACILITY : Crystal River Unit 3

REPORT DATE : April 23, 1984

OCCURRENCE DATE: May 3, 1982

IDENTIFICATION OF OCCURRENCE:

A Reactor Building pressure indicator inoperable contrary to Technical Specification 3.3.3.6.

CONDITIONS PRIOR TO OCCURRENCE:

Mode 1, POWER OPERATION (90%)

DESCRIPTION OF OCCURRENCE:

At 1100, during normal operation, Reactor Building pressure indicator (BS-16-PI) was not indicating correctly. Maintenance was initiated and operability was restored on May 3, 1982.

DESIGNATION OF APPARENT CAUSE:

The cause of this event is attributed to instrument drift.

ANALYSIS OF OCCURRENCE:


Redundancy was provided by an alternate Reactor Building pressure channel. There was no effect upon the health or safety of the general public.

CORRECTIVE ACTION:

The pressure transmitter was recalibrated per Surveillance Procedure SP-162. An engineering evaluation was conducted to determine if calibration frequency should be increased. The evaluation concluded that replacing the transmitter would solve the problem better than increasing the frequency of calibration. The Bailey transmitters, BS-16-PT and BS-17-PT, were replaced with Rosemount transmitters.

FAILURE DATA:

This is the third occurrence for Reactor Building pressure channel (BS-16-PI), and this is the eighth report under this Specification.



**Florida
Power**
CORPORATION

April 23, 1984
3F0484-17

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Licensee Event Report No. 82-033, Rev. 1

Dear Sir:

Enclosed is Revision I to Licensee Event Report No. 82-033.

Should there be any questions, please contact this office.

Sincerely,

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

AEF/feb

Enclosure

cc: Mr. James P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30303

IE22
1/1