

LER 76-15/3L
LICENSEE EVENT REPORT

CONTROL BLOCK 1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME: 01 N Y R E G I 1
 LICENSE NUMBER: 00-000000-000
 LICENSE TYPE: 41111
 EVENT TYPE: 03
 CATEGORY: 01 CONT
 REPORT TYPE: L
 REPORT SOURCE: L
 DOCKET NUMBER: 050-0244
 EVENT DATE: 042476
 REPORT DATE: 052476

EVENT DESCRIPTION

02 During normal operation air ejector and blowdown radiation monitors alarmed. Analysis
 03 of "B" SG blowdown showed iodine activity from a calculated leak rate of 0.06 gpm.
 04 Eddy current (ec) testing verified the leaking tube. Twelve others in adjacent area which
 05 appeared to have similar ID type indications at approx. 2½ to 3" above the tube sheet
 06 were all plugged. Additional ec testing was conducted (cont'd. on attached sheet)

SYSTEM CODE: 07 C B
 CAUSE CODE: E
 COMPONENT CODE: H T E X C H
 PRIME COMPONENT SUPPLIER: N
 COMPONENT MANUFACTURER: W 1 2 0
 VIOLATION: N

CAUSE DESCRIPTION

08 The investigation of steam generator tube failures is continuing. The steam generator
 09 is a Westinghouse Series 44, using inconel tubes size 0.875 OD with 0.050 inch walls.
 10

11 FACILITY STATUS: E
 % POWER: 099
 OTHER STATUS: NA
 METHOD OF DISCOVERY: C
 DISCOVERY DESCRIPTION: Rad monitors and sample analysis
 12 FORM OF ACTIVITY RELEASED: Z
 CONTENT OF RELEASE: Z
 AMOUNT OF ACTIVITY: NA
 LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES

13 NUMBER: 000
 TYPE: Z
 DESCRIPTION: NA

PERSONNEL INJURIES

14 NUMBER: 000
 DESCRIPTION: NA

OFFSITE CONSEQUENCES

15 NA

LOSS OR DAMAGE TO FACILITY

16 TYPE: Z
 DESCRIPTION: NA

PUBLICITY

17 Press release was made.

ADDITIONAL FACTORS

18 NA

19

8304070585 760524
 PDR ADOCK 05000244
 S PDR

NAME: Leon D. White, Jr.

PHONE: 716-546-2700, ext. 2420

Licensee Event Report
Reportable Occurrence 50-244/76-15

Event Description (cont'd.)

(approximately 1,000 tubes) to determine if the pattern of degradation existed in other peripheral tubes beyond the locality of the leak. One additional tube, not in the periphery, was indicated to require plugging. (Reportable Occurrence 76-15, 30-day).



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

May 24, 1976


Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 76-15 (30-day report), "B" Steam
Generator tube leak
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:

In accordance with Technical Specifications, Article 6.9.2b, the attached report of Reportable Occurrence 76-15, 30-day, is hereby submitted. Two additional copies of this letter and the attachment are enclosed.

Very truly yours,


L. D. White, Jr.

Attachment

cc: Dr. Ernst Volgenau (30)
Mr. William G. McDonald (3)

5346

COPY SENT REGION I