



Douglas R. Gipson  
Senior Vice President  
Nuclear Generation

Fermi 2  
6400 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-5249

10 CFR 50.73

May 25, 1995  
NRC-95-0053

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington D.C. 20555

Reference: Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 95-005-00

Please find enclosed LER 95-005, Revision 0, dated May 25, 1995, for a reportable event that occurred on April 25, 1995. A copy of this LER is also being sent to the Regional Administrator, USNRC Region III.

The following commitments are made in this LER:

1. The circuit boards that were replaced as part of the troubleshooting activities will be tested to attempt further cause determination to the component level.
2. Investigation into the pressure regulator monitoring system (PRMS) interface with the pressure regulator control circuitry will be conducted to determine the nature of the unexpected impact of the PRMS circuitry on the pressure regulator control circuitry.
3. An engineering evaluation is being performed to evaluate whether to pursue a long term design modification for reverse power tripping of the CF and CM breakers.


9505310471 950525  
PDR ADDCK 05000341  
S PDR

*Trill*

May 25, 1995  
NRC-95-0053  
Page 2

If you have any questions, please contact Ken Riches, Compliance Engineer at  
(313) 586-5529.

Sincerely,



Enclosure: NRC Forms 366, 366A

cc: T. G. Colburn  
J. B. Martin  
M. P. Phillips  
P. L. Torpey  
A. Vogel  
Region III

Wayne County Emergency  
Management Division