



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Rhode Island Atomic Energy Commission  
NUCLEAR SCIENCE CENTER  
South Ferry Road  
Narragansett, R.I. 02882-1197

April 17, 1984

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region 1  
631 Park Avenue  
King of Prussia, Pa. 19406

License R-95  
Docket 50-193

Gentlemen:

This letter will confirm an incident report telephoned by A. Francis DiMeglio, R. I. Atomic Energy Commission to Stephen Long, Headquarters at about 7:40 a.m. on Monday April 16, 1984.

At about 7:10 a.m., April 16, 1984 a failure occurred in the long distance telephone lines which carry the signals from our burglar alarm, police calls, and supervisory system from the Science Center to the continuously manned station of the R. I. Electric Protective Company in Providence. The phone lines between the Center in Narragansett and the Narragansett Police which transmit burglar alarm and police signals to the Narragansett Police were not affected.

The R. I. Electric Protective Company, using established procedures, notified the staff which had already begun to assemble at the Center for the normal working day. Therefore, manual observation of the monitored functions began at 7:25 a.m.

The phone lines were restored by 1:10 p.m. There were no consequences at the facility.

Very truly yours,

A. Francis DiMeglio  
Director

AFD:ag

8404270197 840417  
PDR ADOCK 05000193  
S PDR

1E22  
70