

LER 76-09/3L
LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME: 01 N Y R E G 1 14
 LICENSE NUMBER: 00 - 000000 - 00 25
 LICENSE TYPE: 4 1 1 1 1 30
 EVENT TYPE: 0 3 32
 CATEGORY: 01 CONT 57 58
 REPORT TYPE: L 59
 REPORT SOURCE: L 60
 DOCKET NUMBER: 0 5 0 - 0 2 4 4 68
 EVENT DATE: 0 2 2 7 7 6 74
 REPORT DATE: 0 3 2 2 7 6 80

EVENT DESCRIPTION

02 During preventive maintenance circuit breaker testing with the plant in refueling mode 80
 03 Bus 18 breaker from "A" emergency generator tripped prematurely. Investigation 80
 04 showed phase C overcurrent trip relay actuated 6 sec. earlier than desired. Over- 80
 05 current relay was replaced. (Reportable Occurrence 76-09, 30-day) 80
 06 80

SYSTEM CODE: EE 10
 CAUSE CODE: E 11
 COMPONENT CODE: R E L A Y X 17
 PRIME COMPONENT SUPPLIER: N 43
 COMPONENT MANUFACTURER: W 1 2 0 47
 VIOLATION: N 48

CAUSE DESCRIPTION

08 NA Relay is Westinghouse overcurrent tripping device, 1600 80
 09 amp 60 Hz style no. 24Y4712BA8 long delay/short delay. Identical replacement relay 80
 10 was bench tested and field tested satisfactorily. 80

FACILITY STATUS: H 9
 % POWER: 0 0 0 10 12 13
 OTHER STATUS: NA 44
 METHOD OF DISCOVERY: b 45
 DISCOVERY DESCRIPTION: NA 46
 FORM OF ACTIVITY RELEASED: Z 9
 CONTENT OF RELEASE: Z 10 11
 AMOUNT OF ACTIVITY: NA 44
 LOCATION OF RELEASE: NA 45 80

PERSONNEL EXPOSURES

13 0 0 0 11
 TYPE: Z 12
 DESCRIPTION: NA 13 80

PERSONNEL INJURIES

14 0 0 0 11
 DESCRIPTION: NA 12 80

OFFSITE CONSEQUENCES

15 NA 80

LOSS OR DAMAGE TO FACILITY

16 Z 10
 DESCRIPTION: NA 80

PUBLICITY

17 NA 80

ADDITIONAL FACTORS

18 Test provides for application of 3 times rated breaker current. The device did meet 80
 19 Westinghouse recommended criteria, but not those established as station practice. 80

NAME: Charles V. Hartlieb

PHONE: 716/546-2700, ext. 291-216



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

March 22, 1976



Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 76-09 (30-day report), Bus 18 breaker
from "A" Emergency Generator overcurrent relay
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:

In accordance with Technical Specifications, Article 6.9.2b, the attached report of Reportable Occurrence 76-09, 30-day, is hereby submitted. Two additional copies of this letter and the attachment are enclosed.

Very truly yours,

L. D. White, Jr.

Attachment

cc: Mr. John G. Davis (30)
Mr. William G. McDonald (3)

3071