

western union

Telegram

NNNN(0852P EDT)...

==DEB462 SSA087 DE CSA004 (ECCJ24107 OCT 21 AM 8 51

(CH 293CC116241) PD=W U TELEG JOL 0849 P EDT10/20/71=ZCZC

MR BOYCE GRIER DIRECTOR DIVN 9 PD TDJL MORRIS ILL

COMPLIANCE REGION III: 20=

=U S ATOMIC ENERGY COMM=

799 ROOSEVELT RD GLENELLYN ILL=

BT=SUBJECT DPR19 DRESDEN NUCLEAR POWER STATION 2.=THIS
WILL CONFIRM CONVERSATION 1600 HOURS THIS DATE WITH E=
JORDAN REGARDING EXCEEDING SECONDARY CONTAINMENT
REQUIREMENTS=SPECIFIED IN 3.7.C.1 FOR A PERIOD OF SEVERAL
HOURS THIS DATE.=

THE CONDITION RESULTED WHEN BOTH AIR LOCK DOORS TO
THE UNIT 3 X--AREA WERE LEFT AJAR TO PERMIT EXTENSION OF

WU 1201 (R 5-69)

AN ELECTRICAL EXTENSION=CORD INTO THE AREA TO FACILITATE
MAINTENANCE IN THE AREA. THIS=WAS IN VIOLATION OF
ESTABLISHED PROCEEDURES. UNIT TWO WAS=OPERATING AT
THE TIME WITH UNIT 3 IN COLD SHUT DOWN THE=REQUIREMENTS
FOR COMBINED SECONDARY CONTAINMENTS ARE BEING=REEMPHASIZED
WITH PERSONNEL OF THE DEPARTMENT=REPONSIBLE FOR THE
ACTION. SECONDARY CONTAINMENT WAS=RESTORED IMMEDIATELY
FOLLOWING MANAGEMENT NOTIFICATION OF=THE SITUATION AT
0930. THIS IS REPORTED UNDER SECTION 6.6.A.3=OF THE
TECHNICAL SPECIFICATIONS.=

H K HOYT SUPT COMMONWEALTH EDISON DRESDEN NUCLEAR
POWER STATION=RURAL ROUTE 1 MORRIS ILL.=

8304080007 711020
PDR ADOCK 05000237
S PDR

1 4783

80-2660

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947) AECM 0240

See me about this.

For conc ce.

For action.

Note and return.

For signature.

For information.

TO (Name and unit)

J. G. Keppler
CO:HQ

INITIALS

DATE

REMARKS

TWX INCIDENT REPORT - DRESDEN 2 (50-237)

TO (Name and unit)

INITIALS

DATE

REMARKS

TO (Name and unit)

INITIALS

DATE

REMARKS

FROM (Name and unit)

G. Fiorelli
CO:III

REMARKS

In accordance with PI 1000, attached is the original TWX
report dated 10-21-71 reporting failure to maintain
secondary containment integrity.

PHONE NO.

DATE

358-2660

10-22-71

Copy sent PDR

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1965 O-294-019