

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2										DOCKET NUMBER (2) 0 5 0 0 0 3 6 1				PAGE (3) 1 OF 0 1		
TITLE (4) MANUAL CONTROL ROOM ISOLATION SYSTEM (CRIS) ACTUATION																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 3	2 4	8 4	8 4	0 1 1 8	0 0 0	4 2	3 8	4	SONGS UNIT 3				0 5 0 0 0 3 6 2			
OPERATING MODE (9) 1			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)													
POWER LEVEL (10) 1 0 0		20.402(b)				20.405(c)				<input checked="" type="checkbox"/> 50.73(a)(2)(iv)		73.71(b)				
		20.405(a)(1)(i)				50.36(c)(1)				<input checked="" type="checkbox"/> 50.73(a)(2)(v)		73.71(c)				
		20.405(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)		OTHER (Specify in Abstract below and in Text, NRC Form 366A)				
		20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)						
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)						
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(x)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME J. G. HAYNES, STATION MANAGER										TELEPHONE NUMBER 7 1 1 4 4 9 2 1 - 7 7 0 0						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC						
X	VIA	RIT	N3105	N												
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)												<input checked="" type="checkbox"/> NO				

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On March 24, 1984, at 1800, with Units 2 and 3 in Mode 1 at 100 percent power, with radiation monitor 2/3RT-7824 (EIIS Component Code RIT) inoperable for monthly surveillance, the remaining Control Room Isolation System (CRIS) radiation monitor, 2/3RT-7825, was declared inoperable when a dirty filter caused a low flow alarm. In accordance with Limiting Conditions for Operation (LCO) 3.3.2, Action Statement 'b', and 3.3.3.1, Action Statement 'b', the CRIS was manually initiated at 1850, actuating the Control Room Emergency Air Cleanup System (EIIS System Code VI).

The filter was changed and radiation monitor 2/3RT-7825 was declared operable at 2040 on March 24, 1984. The CRIS was secured and the Control Room ventilation system was returned to normal. This incident is considered to be an isolated occurrence and no further corrective action is planned.

There are no reasonable or credible circumstances which could have increased the severity of this occurrence. The health and safety of Station personnel or the public were not affected by this occurrence.

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

SCE

J. G. HAYNES
STATION MANAGER

April 24, 1984

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Docket 50-361 and 50-362
30-Day Report
Licensee Event Report No. 84-018
San Onofre Nuclear Generating Station Units 2 and 3

Pursuant to 10 CFR 50.73(a)(2)(iv) and 50.73(a)(2)(v), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the March 24, 1984, manual initiation of the Control Room Isolation System (CRIS).

If you require any additional information, please so advise.

Sincerely,

J. G. Haynes

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)
J. B. Martin (Regional Administrator, NRC Region V)
Institute of Nuclear Power Operations (INPO)

*IE22
1/1*