



Telegram

DEB904 SPA009 SSA203

DE JLA104 NL RC PDB=MORRIS ILL 7= .

MR. BOYCE GRIER, DIRECTOR AEC COMPLIANCE REGION THREE=  
799 ROOSEVELT RD GLEN ELLYN ILL 60137=

DPR19 AND 25 DRESDEN NUCLEAR POWER STATION UNITS 2  
AND 3. THIS WILL CONFIRM CONVERSATION 1430 THIS DATE  
WITH E A JORDON REGARDING AN UNPLANNED LIQUID RELEASE  
OCCURRING FROM 0945 TO 1105 THIS DATE REPORTABLE UNDER  
SECTION 66A3 THIS UNPLANNED RELEASE OCCURED AS A  
RESULT OF AN ERROR IN VALVE LINE UP CAUSING B FLOOR  
DRAIN SAMPLE TANK RELEASE AT A RATE ESTABLISHED FOR THE  
FLOOR DRAIN SAMPLE TANK PRIOR TO ESTABLISHING THE  
PROPER DISCHARGE RATE OF THE B TANK. THE RESULTING

WU 1201 (R 5-69)

ACTIVITY IN THE DISCHARGE WATER WAS 30 PICOCURIES  
PER LITER OR 30 PERCENT OF THE ALLOWABLE. A REVIEW  
OF FACTORS WHICH CONTRIBUTED TO THE ERROR IS BEING  
REVIEWED AND ACTION IS BEING TAKEN TO PREVENT RECURRENCE=  
H K HOYT SUPT. DRESDEN NUCLEAR POWER STATION=

*1S/2BX 8/16/71*

AUG 10 1971

*X-Docket No. 50-249*

TELEPHONE NO. \_\_\_\_\_

TELEPHONE TO \_\_\_\_\_

TIME DELAYED \_\_\_\_\_

*Apr 950a mld*

8304080078 710811  
PDR ADOCK 05000237  
G PDR

Copy sent PDR

WU 1201 (R 5-69)

MEMO ROUTE SLIP		See me about this:	For conc. e.	For action.
Form AEC-93 (Rev. May 14, 1947) AECM 240		Note and return:	For signature.	For information.
TO (Name and unit): J. Keppler CO:HQ	INITIALS  DATE	REMARKS TWX INCIDENT REPORT - DRESDEN 2 & 3 (50-237 and 50-249)		
TO (Name and unit):	INITIALS  DATE	REMARKS		
TO (Name and unit):	INITIALS  DATE	REMARKS		
FROM (Name and unit): D. M. Hunnicutt CO:III <i>Edford</i>	REMARKS In accordance with PI 1000, attached is the original TWX report dated 8-7-71 reporting an unplanned liquid release.			
PHONE NO.	DATE 8-10-71	14069 Conv sent PDR		

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1965 O-294-619