

**Florida
Power**
CORPORATION

April 23, 1984
3F0484-09

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Technical Specification Change Request No. 110,
Operation of Closed Containment Isolation Valves

Dear Mr. Denton:

Enclosed are three (3) originals and forty (40) copies of Request No. 110 requesting amendment to Appendix A of Operating License No. DPR-72. As part of this request, the proposed pages are enclosed.

This change will allow operation of specific containment isolation valves when they would normally be isolated provided a dedicated operator is posted to isolate the valves when necessary. Operation of these valves is necessary to provide operating flexibility and to fulfill other Technical Specification requirements.

There are several additional containment isolation valves listed which are not currently in the Technical Specifications. These valves were added as a part of the NUREG-0737 modifications (see Change Request No. 82, Attachment C), and are included in this submittal because we are requesting approval to operate some of these valves.


8404300079 840423
PDR ADOCK 05000302
PDR

ADD
11
Rec'd w/track #4,000

April 23, 1984
3F0484-09
Page 2

Florida Power Corporation considers Request No. 110 to be a Class III Amendment per 10CFR170.22 as it involves a single safety issue. Accordingly, a check for four thousand dollars (\$4,000.00) is enclosed.

Sincerely,



G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management


PGH/ddl

cc: Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, GA 30303

STATE OF FLORIDA


COUNTY OF PINELLAS

G.R. Westafer states that he is the Manager, Nuclear Operations Licensing and Fuel Management for Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.



G.R. Westafer
Manager, Nuclear Operations Licensing and Fuel
Management

Subscribed and sworn to before me, a Notary Public in and for the State
and County above named, this 23rd day of April, 1984.



Notary Public

Notary Public, State of Florida at Large,

My Commission Expires: November 19, 1986

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)

FLORIDA POWER CORPORATION)

DOCKET No. 50-302

CERTIFICATE OF SERVICE


G.R. Westafer deposes and says that the following has been served on the Designated State Representative and the Chief Executive of Citrus County, Florida, by deposit in the United States mail, addressed as follows:

Chairman,
Board of County Commissioners
of Citrus County
Citrus County Courthouse
Inverness, FL 32650

Administrator
Radiological Health Services
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, FL 32301


Three (3) copies of Technical Specification Change Request No. 110, requesting amendment to Appendix A of Operating Licensing No. DPR-72.

FLORIDA POWER CORPORATION



G.R. Westafer
Manager
Nuclear Operations Licensing and Fuel
Management

SWORN TO AND SUBSCRIBED BEFORE ME THIS 23rd day of April, 1984.


Notary Public

Notary Public, State of Florida at Large
My Commission Expires: November 19, 1986

(NOTARIAL SEAL)

