

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2										DOCKET NUMBER (2) 0 5 0 0 0 3 6 1				PAGE (3) 1 OF 0 1	
--	--	--	--	--	--	--	--	--	--	--------------------------------------	--	--	--	----------------------	--

TITLE (4) FIRE PROTECTION PROGRAM DISCREPANCIES															
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)					
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER (8)		
0 4	2 4	8 4	8 4	0 2 4	0 0	0 4	2 5	8 4	UNIT 3			0 5 0 0 0 3 6 2		
												0 5 0 0 0 1 1		

OPERATING MODE (9) 1		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)													
POWER LEVEL (10) 1 0 0		20.402(b)		20.405(c)		50.73(a)(2)(iv)		73.71(b)							
		20.405(a)(1)(i)		50.36(c)(1)		50.73(a)(2)(v)		73.71(c)							
		20.405(a)(1)(ii)		50.36(c)(2)		50.73(a)(2)(vii)	X	OTHER (Specify in Abstract below and in Text, NRC Form 366A)							
		20.405(a)(1)(iii)		50.73(a)(2)(i)		50.73(a)(2)(viii)(A)		License Condition 2.G							
		20.405(a)(1)(iv)	X	50.73(a)(2)(ii)		50.73(a)(2)(viii)(B)									
	20.405(a)(1)(v)		50.73(a)(2)(iii)		50.73(a)(2)(x)										

LICENSEE CONTACT FOR THIS LER (12)

NAME J. G. HAYNES, STATION MANAGER		TELEPHONE NUMBER	
		AREA CODE 7 1 4	4 9 2 - 7 7 0 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	X NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

As reported on April 24, 1984, pursuant to 10 CFR 50.72(b)(1)(ii)(B) and License Condition 2.G., the preparation of the updated Fire Hazards Analysis (FHA) resulted in the issuance of two Nonconformance Reports (NCR's) identifying discrepancies involving cable separation and fire wraps.

The conditions identified in these 2 NCR's constitute additional examples of deficiencies reported previously in LER 84-015. Corrective actions, described in LER 84-015, will be to wrap or separate appropriate cables or cable trays, or to revise the FHA to clarify appropriate cable wrapping requirements.

This report is also submitted to fulfill the requirements of License Condition 2.G. relating to License Conditions 2.C.(14)a and 2.C.(12)a of Operating Licenses NPF-10 and NPF-15 for Units 2 and 3, respectively.

IE24
1/18404300103 840425
PDR ADOCK 05000361
S PDR

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

TELEPHONE
(714) 492-7700

April 25, 1984

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Docket No. 50-361 and 50-362
30-Day Report
Licensee Event Report No. 84-024
San Onofre Nuclear Generating Station, Units 2 and 3

- References: (1) Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated April 5, 1984, Licensee Event Report 84-015
- (2) Letter, K. P. Baskin (SCE) to H. R. Denton (NRC),
dated March 19, 1984, "FHA Update Consistent
with 10 CFR 50.71(e)"

Pursuant to 10 CFR 50.73 and License Condition 2.G to Facility Operating Licenses NPF-10 and NPF-15 for Units 2 and 3, respectively, this submittal provides the 24-hour telephone report, 14-day Follow-up report, and Licensee Event Report (LER) Number 84-024 (Docket No. 50-361) for apparent fire protection program discrepancies. Since these occurrences involved shared systems between Units 2 and 3, a single LER for Unit 2 is enclosed in accordance with NUREG-1022.


As indicated in Reference 1, discrepancies have been discovered during our continuing review (see LER 84-001, Docket No. 50-361) for the preparation of the updated Fire Hazards Analysis (FHA) (Reference 2). Two NCR's, additional examples of deficiencies reported previously in Reference 1, have been identified. Corrective actions, described in Reference 1, will be implemented. The health and safety of plant personnel and the public were not affected by these discrepancies.

IERA
11

April 25, 1984

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in dark ink, appearing to read "J. B. Martin", with a stylized flourish at the end.

Enclosure: LER No. 84-024

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, NRC Region V)

Institute of Nuclear Power Operations (INPO)