

METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 480 MIDDLETOWN, PENNSYLVANIA 17057

TELEPHONE 717-944-4041

September 27, 1974

Mr. J.P. O'Reilly, Director
Directorate Of Regulatory Operation
Region I
631 Park Avenue
King Of Prussia, Pa. 19406

Operating License DPR-50
Docket 50-289

Subject: Environmental Incident No. EI 74-9

Dear Mr. O'Reilly:

This telegram is to confirm the telecon between Mr. Fasano (Region I-AEC), and Joseph J. Colitz (THI-Unit Superintendent) at 1610 hours 27 September 1974.

Violation of the Environmental Technical Specification 2.2.1.a (page 7) in that the free chlorine component measured at the plant river discharge equalled 0.1 ppm on 26 September 1974.

Analysis of the free chlorine component in the plant river discharge 10 minutes after the start of a chlorination cycle indicated 0.1 ppm.

To insure the free chlorine component in the plant river discharge remains below .1 ppm, the chlorination addition rate has been reduced from 300 #/day to 250 #/day.

Very truly yours,

J.J. Colitz

J.J. Colitz
Unit Superintendent
THI Nuclear Station

JJC/dnn

8304080114 741004
PDR ADOCK 05000219
S PDR