

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

J. O. SCHUYLER

VICE PRESIDENT

NUCLEAR POWER GENERATION

April 24, 1984

PGandE Letter No.: DCL-84-151

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-76
Docket No. 50-323
Diablo Canyon Units 1 and 2
IE Bulletin No. 83-08 - Electrical Circuit Breakers
With An Undervoltage Trip Feature

Gentlemen:

This supercedes, in its entirety, PGandE's April 4, 1984 (DCL-84-129) response to IE Bulletin No. 83-08.

PGandE has reviewed IE Bulletin No. 83-08, "Electrical Circuit Breakers With An Undervoltage Trip Feature In Use In Safety-Related Applications Other Than The Reactor Trip System." Diablo Canyon Units 1 and 2 do not use any of the subject circuit breakers, including Westinghouse types DB and DS, and General Electric type AK-2 for safety-related applications other than the reactor trip system. It was determined that there are no similar applications using the undervoltage trip feature.

IE-11
11

Document Control Desk
April 24, 1984
PGandE Letter No.: DCL-84-151
Page Two

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Subscribed to in San Francisco, California this 24th day of April, 1984.

Respectfully submitted,

Pacific Gas and Electric Company

By *J. O. Schuyler*
J. O. Schuyler
Vice President
Nuclear Power Generation

Robert Ohlbach
Philip A. Crane, Jr.
Richard F. Locke
Attorneys for Pacific
Gas and Electric Company

By *Richard F. Locke*
Richard F. Locke

Subscribed and sworn to before me
this 24th day of April, 1984.

C. T. Neal - Madison
C. T. Neal-Madison, Notary Public in
and for the City and County of
San Francisco, State of California

My commission expires December 27, 1985.

cc: J. B. Martin
Service List

