

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-1531

April 25, 1984

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Attention: Ms. E. G. Adensam, Chief  
Licensing Branch No. 4

Re: Catawba Nuclear Station  
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

Section 7.3.2.2 of the Catawba Safety Evaluation Report discusses Confirmatory Item 26, Compliance with IE Bulletin 80-06. This bulletin requests a review of the ESF systems to verify that no device will change position solely because of the reset of the actuation signal. Such a review was performed and documented for the Staff. Further verification that the installed instrumentation and controls are in compliance with the requirements of IE Bulletin 80-06 is provided during pre-operational test TP/1/A/1200/03B, "Engineered Safeguards Feature (ESF) Test." Testing of Train A has been completed and this function was verified for equipment that was operated by an ESF signal. Train B testing is scheduled for April 29, 1984. The completed procedure will be available after this date at the Catawba site for review by the NRC.

Very truly yours,



Hal B. Tucker

ROS/php

cc: Mr. James P. O'Reilly  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303

NRC Resident Inspector  
Catawba Nuclear Station

Mr. Robert Guild, Esq.  
Attorney-at-Law  
P. O. Box 12097  
Charleston, South Carolina 29412

Palmetto Alliance  
2135½ Devine Street  
Columbia, South Carolina 29205

Mr. Jesse L. Riley  
Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

*13001  
1/0*

8404300159 840425  
PDR ADOCK 05000413  
E PDR