

WESTERN UNION INCOMING

1841

BETH  
008

710P EDT MAY \*

USAEC HQS G1WN

1971 MAY 28 PM 8 29

50-237

WD WSH

U.S. ATOMIC ENERGY COMM.  
1WX UNIT

TLX4222 (45)DEA119

DE JLA141 HS PDU WUK MORRIS ILL 28 125P CDT

DIRECTOR DIVN OF REACTOR LICENSING

US ATOMIC ENERGY COMMISSION

WASHDC 20545

THIS IS TO INFORM YOU OF AN UNPLANNED RELEASE OF RADIO ACTIVE  
ACTIVITIES WHICH OCCURED AT ABOUT 6AM ON MAY 27 1971. THIS  
RELEASE WAS CAUSED BY A RUPTURE IN THE HPCI RETURN LINE TO  
THE CONDENSATE STORAGE TANK DURING A SURVEILLANCE TEST WHICH  
ALLOWED SOME OF THE CONDENSATE STORAGE TANK WATER TO FLOW INTO  
A STORM SEWER. PRELIMINARY CALCULATIONS INDICATES THAT THE  
RELEASE HAD NO DISCERNIBLE DETRIMENTAL EFFECT ON THE ENVIRONMENT.  
THE LETTER REQUIRED UNDER SECTION 6.8.4.3 OF THE TECHNICAL  
SPECIFICATION WILL PROVIDE ADDITIONAL INFORMATION

W R HOYT SUPT DRESDEN NUCLEAR POWER STATION

613P EDT 28MAY71

USAEC HQS G1WN

IS/O'R/Staff 6/24/71  
RAC  
LX



2535

8304080232 710601  
PDR ADOCK 05000237  
Q PDR

12047

COPY SENT REGION