



Telegram

DEB325 KB226 K VEC036 WT

1745) 6. 4. 11

(DE JLA149) SC PDF MORRIS ILL 5 357P CST:

MR BOYCE H GREER USATOMIC ENERGY COMM

DIVN OF COMPLIANCE REGION 3

799 ROOSEVELT RD GLEN ELLYN ILL

THIS IS TO CORRECT OUR EARLIER TELEGRAM OF 4-5-71 IT SHOULD READ THIS IS TO INFORM YOU OF A WIRING ERROR DISCOVERED ON APRIL 4 1971 THAT RESULTED IN A PHASE REVERSAL ON THE BACK UP POWER SUPPLY TO THE REACTOR INJECTION VALVE OF THE LOW PRESSURE COOLANT INJECTION (LPCI) SYSTEM THIS WOULD HAVE PREVENTED THEM FROM OPERATING AS DESIGNED WHEN ON BACK UP POWER AND IS REPORTABLE UNDER SECTION 6.6.A.1 AND 6.6.B.2 OF THE DPR

WU 1201 (R 5-69)

19 TECHNICAL SPECIFICATIONS THE WIRING ERROR WAS CORRECTED IMMEDIATELY AND AN INVESTIGATION IS IN PROGRESS TO DETERMINE HOW IT OCCURRED THE BETTER REQUIRED UNDER SECTION 6.6.B.2 WILL PROVIDE AMPLYIFYING
=H K HOYT SUPT DRESDEN NUCLEAR POWER STATION.=

IS/O'R/Staff 4/20/71
R4E
LK

8304080332 710416
PDR ADOCK 05000237
S PDR

TELETYPE
TIME 10:47 AM
BY [signature] TO BE [signature]

=4-5-71 4 1971 (LPCI) 6.6.A.1 6.6.B.2 DPR 19 6.6.2.

WU 1201 (R 5-69)

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947)

See me about this.

For concurre

For action.

Note and return.

For signature.

For information.

TO (Name and unit) J. P. O'Reilly CO:HQ	INITIALS DATE	REMARKS TWX INCIDENT REPORT - DRESDEN 2 (50-237)
TO (Name and unit)	INITIALS DATE	REMARKS
TO (Name and unit)	INITIALS DATE	REMARKS
FROM (Name and unit) Gaston Fiorelli CO:III <i>Gaston Fiorelli</i>	REMARKS In accordance with PI 1000, attached is the original and three copies of a TWX report dated 4-5-71 reporting a wiring error.	
PHONE NO.	DATE 4-7-71	11876

USE OTHER SIDE FOR ADDITIONAL REMARKS

U. S. GOVERNMENT PRINTING OFFICE : 1957 - O-422007