

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947)		See me about this. Note and return.	For concurr. For signature.	For action. For information.
TO (Name and unit) J. P. O'Reilly CO:HQ	INITIALS DATE	REMARKS TWX INCIDENT REPORT - DRESDEN 2 (50-237)		
TO (Name and unit)	INITIALS DATE	REMARKS 50-237		
TO (Name and unit)	INITIALS DATE	REMARKS 11/4/76		
FROM (Name and unit) G. Fiorelli CO:III <i>G. Fiorelli</i>	REMARKS In accordance with PI 1000, attached is the original and three copies of a TWX report dated 3-30-71 reporting an inoperable core spray valve.			
PHONE NO.	DATE 3-31-71			

USE OTHER SIDE FOR ADDITIONAL REMARKS

U. S. GOVERNMENT PRINTING OFFICE: 1957-O-422007

western union

Telegram

=(456)====

==DEB848 SPA074 SPG016 SSH455

DE JLA135 JN P=MORRIS ILL 29 450P CST=

MR BOYCE H GRIER= REGION 3 COMPLIANCE

US ATOMIC ENERGY COMMISSION GLENELLEN ILL=

BE ADVISED OF EVENT PER SECTION 6.6A 1 OF TECHNICAL SPECIFICATION FOR DPR19 CORE SPRAY VALVE 1402-24B WAS FOUND INOPERABLE DURING REQUIRED SURVEILLANCE TESTING DUE TO THE LPCI SYSTEM BEING OUT OF SERVICE FOR TESTING CORE ALTERNATION WERE IMMEDIATELY TERMINATED UNTIL THIS VALVE WAS MANUALLY OPENED AND THE CORE SPRAY SYSTEM WAS AGAIN DECLARED OPERABLE=

HH K HOYT SUPT DRESDEN NUCLEAR POWER STATION=

151081 Staff 4/21/71 MAR 31 1971

8304080462 710401
PDR ADOCK 05000237
Q PDR

11828