

16.5 Reporting Requirements

Specification

1. As part of the ~~Semiannual~~Annual Monitoring Report, described in Section 15.7.8.4.A of Appendix A, the following shall be reported:
 - a. All scheduled and unscheduled chemical discharge to the condenser cooling water.
 - b. A description of circulating water system operation for each unit which includes ambient temperature, intake temperature, discharge temperature, and circulating water system flow.

9506010081 950524
PDR ADDCK 05000266
P PDR