

TO:
James G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: 5-8-75
Telecopied Data
or
Teletype: CE 1:15 p.m.
DC 11:45 a.m.
By AM

cc:
J. F. O'Leary, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: DPR- 19, Dresden Nuclear Power Station, Unit 2:

This will confirm a conversation with MR. JOHNSON of
your office at 1130 hrs this date concerning FAILURE OF
CONTROL ROD DRIVE RETURN LINE CHECK VALVE
-301-98 TO PASS LOCAL LEAK RATE TEST AT
130 7 MAY 1975. CHECK VALVE WILL BE REPAIRED
BEFORE TO START-UP.

8304110142 750508
PDR ADOCK 05000237
S PDR

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

To Call:
CE - 3-858-2660x16 (auto) - on 6
DC - 9-1-301-492-7617 (auto)
WB - 815-942-4449/4321

50-237
Inquiry
Rec'd 1:25
5/8/75
B. E. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
E.E. #1
Norris, IL 60450