



# Telegram

1973 APR -5 PM 3:20

VEE190(1619)(1-023299C095)PD 04/05/73 1616

ICS IPMVEIA MVN

01200 TDVE MORRIS IL 04-05 240P CST

PMS BOYCE GRIER DIRECTOR DIVN OF COMPLIANCE REGION 3

US ATOMI?ENGERY COMMISSION

WUX 799 ROOSEVELT RD GLENELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT TWO

THIS WILL CONFIRM THE CONVERSATION WITH MR MAURA OF YOUR OFFICE  
AT 1420 HOWEARD THIS DATE CONCERNING TRIP OF MO-2-1301-1 BREAKER.  
ISOLATION CONDENSOR STEAM LINE ISOLATION VALVE WAS IN ITS  
NORMALLY OPEN POSITION. IT WOULD HAVE PERMITTED NORMAL FUNCTION OF  
THE ISOLATION CONDENSOR SYSTEM, BUT WOULD NOT HAVE ISOLATED IN  
EVENT OF LINE BREAK. LAST KNOWN OPERATION WAS MONDAY AFTERNOON APRIL  
2, 1973

W P WORDEN SUPT DRESDEN NUCLEAR POWER STATION RTE 1 MORRIS ILL

(RS-00) 15-942-2920 APR 9 1973

IS PHYSICAL DELIVERY requested?

AGENT SECTION

ADDRESSEE SECTION

Nbr.

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

8304120083 730413  
PDR ADOCK 05000237  
PDR