



Telegram

DEB723 SSC073

DE LLA139 XRT0038 DP PD-JLN JOLIET ILL 4 953PM #1 59
BOYCE H GRIER DIRECTOR DIV OF COMPLIANCE REGION 3
US ATOMIC ENERGY COMMISSION-

799 ROOSEVELT RD GLENELLYN ILL 60137-

THIS WILL CONFIRM CONVERSATION 1630 THIS DATE WITH HUGH
DONCE REGARDING FAILURE OF MAIN STEAM ISOLATION VALVES
ON UNIT #2 TO CLOSE DURING BI WEEKLY SERVICE AND TESTING
LUTINCEN 0100 & 0200 ON 12-4-70. FAILURE TO CLOSE
OCCURRED IN THE MANUAL OPERATING MODE ON INITIAL TESTING
ID 2A 2B AND 2 C VALVES HOWEVER ALL PARTIAL CLOSURE TEST
OPERATIONS WERE NORMAL 2A VALVE CLOSED. ON THE SECOND
OPERATION WHERE AS ID 2B 2C OPERATED PROPERLY ONLY AFTER
DEC 8 1970

SEVERAL OPERATIONS DURING SYSTEM COOL DOWN AT 0200
THIS DATE ORDERLY SHUT DOWN WAS INITIATED AS DATE
REQUIRED BY 3 7 D 3 AND SUB CRITICAL ATTAINED 0744
PILOT VALVE CONDITION APPEARED CLEAN BUT CLOSE
INSPECTION REVEALED A VERY THIN FILM VALVE OPERATION
IMPROVES OTHERWISE UNTIL CLEAN DRY CLOTH. THOROUGH
CLEANING OF ALL PILOTS TO BE ACCOMPLISHED FOLLOWED DRY
RETIMING AND TESTING ON HEAD UP AND UNIT LOADING AIR
SUPPLY BEING CHECKED. HIGH TEMPERATURE 150 TO 200 F ON
INBOARD PILOT NOTCH AT TIME OF MALFUNCTION APPEARS
UNREALTED AND CAUSE WILL BE INVESTIGATED TIMING OF
1A&2D MSIV WERE 5.8 AND 5.7 SECONDS ALTHOUGH OTHER

OPERABLE VALVES WERE NORMAL-

H K HOYT STATION SUPERINTENDENT DRESDEN STATION
RR#1 MORRIS ILLINOIS COMMONWEALTH EDISON CO-

IS/OR/Staff 12/30/70
RHE

8304120198 701211
PDR ADOCK 05000237
S PDR

Ru 1209P
Ru 239P

858-2660
TELEPHONED TO SB
TIME DELAYED 10000
BY JC TO BE 27

04723

1630 HUGH DONCE #2 0100 0200 12-4-70 ID A2B 2C 2A ID
2B 2C 0200 3 7 D 3 0744 150 200 F 1A/2D MSIV 5.8 5.7=

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1967)

See me about this.

For concurrence

For action.

Note and return.

For signature.

For information.

TO (Name and unit) J. P. O'Reilly CO:HQ	INITIALS <i>M 12/50</i> DATE	REMARKS
TO (Name and unit)	INITIALS DATE	REMARKS
TO (Name and unit)	INITIALS DATE	REMARKS
FROM (Name and unit) H. D. Thornburg CO:III	REMARKS In accordance with PI 1000, item .08.a., attached is the <i>att 12-5-70</i> original and three copies of a TWX report reporting the failure of MSIV's of Dresden Unit 2 to close.	
PHONE NO.	DATE 12-8-70	04722

USE OTHER SIDE FOR ADDITIONAL REMARKS

U. S. GOVERNMENT PRINTING OFFICE: 1961-O-422007