



50-237 HCN
Telegram

VFC232(1800)(1-027988C081)PD 03/22/73 1757
ICS IRMVEIG MUN
ZCZC 07331 IDVE MORRIS IL 141 03-22 0400P
PMS ROYCE GRIER DIRECTOR DIVN OF COMPLIANCE
REGION 3 US ATOMIC ENERGY COMMISSION
799 ROOSEVELT RD
GLEN ELLYN IL 60137

SUBJECT DPR-19 DRESDEN NUCLEAR POWER STATION UNIT 2 THIS WILL
CONFIRM A CONVERSATION WITH MR. H. DANCE OF YOUR OFFICE AT 1130
HOURS THIS DATE CONCERNING HIGH ABOVE GROUND ACTIVITY "C" WASTE
SAMPLE TANK AT 2/3 RAD WASTE.

ON 3/21/73 A CARRYOVER CONDITION ON THE WASTE CONCENTRATOR CAUSED
HIGH CONDUCTIVITY WATER (MORE THAN 1800 UMHOS) AND HIGH ACTIVITY
WATER TO BE COLLECTED IN THE WAST COLLECTOR. THIS WATER WAS FILTERED
AND SENT TO "C" WASTE SAMPLE TANK. AT 2300 HOURS ON 3/21/73 A
SAMPLE OF THIS TANK SHOWED THE ACTIVITY TO BE 4.05 CURIES. AT THAT

SF-1201 (RS-69)

TIME BOTH NEUTRALIZER TANKS WERE FULL. AS SOON AS POSSIBLE
"C" WASTE SAMPLE WILL BE SENT TO A NEUTRALIZER TANK AND
CONCENTRATED.

A REVIEW OF WASTE CONCENTRATOR ALARMS AND TRIPS WILL BE MADE TO
SEE IF A MODIFICATION CAN BE MADE TO IMPROVE WASTE CONCENTRATOR O
OPERATION

W R WORDEN

SUPT. DRESDEN NUCLEAR POWER STATION
RURAL ROUTE 1, MORRIS IL 60540
942-2920 (815)

8304120650 730330
PDR ADOCK 05000237
S PDR

1973

SF-1201 (RS-69)