



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

May 24, 1976

Director of Nuclear Reactor Regulation
ATTN: Mr. Karl Goller
Assistant Director for Operating Reactors
Division of Reactor Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



Subject: Inspection of Hydraulic Shock Absorbers (Snubbers)
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Goller:

In accordance with Mr. Skovholt's letter of October 1, 1973, concerning periodic inspection of hydraulic shock absorbers (snubbers), an inspection of all snubbers outside of containment was completed on May 11, 1976.

All snubbers were considered operable at this inspection. No fluid additions were necessary.

Very truly yours,

L. D. White, Jr.
L. D. White, Jr.

50-244

8304120753 760524
PDR ADOCK 05000244
G PDR

5342

COPY SENT REGION I