

TELEPHONE
AREA CODE 716 546-2700
Ginna Station
September 26, 1974

Files

Mr. James P. O'Reilly, Director
Directorate of Regulatory Operations
Region 1
U. S. Atomic Energy Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Abnormal Occurrence 74-17: Violation of a limiting condition for operation as established in the Technical Specifications by operating with the accumulators low level below the 1008 cubic feet as established in Technical Specification 3.3.1.1b

Dear Mr. O'Reilly:

This is to confirm my phone call to Mr. John Hannon yesterday to report Abnormal Occurrence 74-17 at Ginna Station.

After Westinghouse alerted us to the possibility that we might have a discrepancy in the volume of borated water in the accumulators at Ginna Station, an immediate investigation was started.

At this time, it appears that the amount of borated water in the accumulators has been between approximately 970 cubic feet and 995 cubic feet, rather than the 1008 cubic feet and 1030 cubic feet as specified in the Ginna Station Technical Specifications.

Further investigations are continuing and the correct volume of borated water will be established in each accumulator as soon as final accurate figures are available.

Your office will be kept informed as to the progress of our investigations.

Very truly yours,

Charles E. Platt

Charles E. Platt
Superintendent

CEP:fah

cc: Mr. J. P. O'Leary, AEC
Mr. G. J. Swarthout, RG&E
Mr. L. D. White, Jr., RG&E

*50-244
incident*

8304140352 741004
PDR ADOCK 05000244
S PDR