


ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649



TELEPHONE  
AREA CODE 716 546-2700

Ginna Station  
August 7, 1974



Mr. James P. O'Reilly, Director  
Directorate of Regulatory Operations  
Region I  
U. S. Atomic Energy Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Subject: Abnormal Occurrence 74-14 - Failure of the 1C Safety Injection Pump  
to Start Manually from Bus 16  
Ginna Station Docket #50-244

Dear Mr. O'Reilly:

This is to confirm my phone call to Mr. Lee Spessard this morning to report  
Abnormal Occurrence 74-14 at Ginna Station.

While conducting Periodic Test (PT-2.1), and following the satisfactory test of  
the 1-A and 1-B Safety Injection Pumps, the 1-C Safety Injection Pump which can  
be operated from either Bus 14 or Bus 16, failed to start manually on Bus 16 the  
first time it was tried. It had started properly from Bus 14, but the first time  
it was tried from Bus 16, it failed to start. The second try was successful and  
the surveillance of the 1-C pump was completed. The 1-C pump was again started  
from Bus 14 and then twice more from Bus 16.

The failure of the 1-C Safety Injection Pump to start from Bus 16 has occurred  
previously on the following dates: June 11, 1973 (Abnormal Occurrence 73-3);  
June 12, 1973 (Abnormal Occurrence 73-4); and April 6, 1974 (Abnormal Occurrence  
74-4).

The PORC met this morning and recommended a thorough inspection of the breaker by  
the Electricians. Any further action that is necessary will be carried out after  
the Electricians' report back to the PORC.

8304140362 740815  
PDR ADOCK 05000244  
S PDR

Very truly yours,

*Charles E. Platt*

Charles E. Platt  
Superintendent

CEP:fah

cc: Mr. J. F. O'Leary, AEC  
Mr. G. J. Swarthout, RG&E  
Mr. L. D. White, Jr., RG&E

8302 I  
COPY SENT REGION